

Figure 26[25] TAC §510.131(c)[§134.131(e)]

[TABLE (3)]

VENTILATION REQUIREMENTS FOR FACILITIES¹

Area designation	Air movement relationship to adjacent areas ²	Minimum air changes of outdoor air per hour ³	Minimum total air changes per hour ⁴	All air exhausted directly to outdoors ⁵	Recirculated by means of room units ⁶	Relative humidity (%) ⁷	Design temperature (degrees F) ⁸
NURSING							
Patient room	---	2	2	---	---	---	70-75
Patient toilet room	In	---	10	Y	---	---	---
Airborne infection isolation room ⁹	In	2	12	---	No	---	75
Isolation alcove or anteroom ⁹	Out	---	10	Y	No	---	---
Patient corridor	---	---	2	---	---	---	---
ANCILLARY							
Radiology¹⁰							
X-ray (diagnostic and treatment)	---	---	6	---	---	---	75
Darkroom	In	---	10	Y	No	---	---
Laboratory							
General ¹⁰	---	2	6	---	---	---	75
Sterilizing	In	---	10	Y	No	---	75
Pharmacy	Out	---	4	---	---	---	75
DIAGNOSTIC AND TREATMENT							
Examination room	---	---	6	---	---	---	75
Medication room	---	---	4	---	---	---	75
Treatment room	---	---	6	---	---	---	75
Physical therapy	In	---	6	---	---	---	75

and hydrotherapy								
Soiled workroom	In	---	10	Y	No	---	---	
or holding								
Clean workroom or holding	Out	---	4	---	---	---	---	
STERILIZING AND SUPPLY								
Sterilizer equipment room ²	In	---	10	Y	No	---	---	
Sterile storage	-- -	---	4	---	---	70 (max)	---	
SERVICE								
Food preparation center ¹¹	-- -	10	---	---	No	---	---	
Warewashing	In	---	10	Y	No	---	---	
Dietary day storage	In	---	2	---	---	---	---	
Laundry, general	--	---	10	Y	---	---	---	
Soiled linen (sorting and storage)	In	---	10	Y	No	---	---	
Clean Linen storage	--	---	2	---	---	---	---	
Soiled linen and trash chute room	In	---	10	Y	No	---	---	
Bedpan room	In	---	10	Y	---	---	---	
Bathroom/Toilet room	--	---	10	Y	---	---	---	75
Janitor's closet	In	---	10	Y	No	---	---	
ADMINISTRATIVE AND SUPPORT SERVICE								
	--	--	2	---	---	30(min)	---	68-73

¹The ventilation rates in this table cover ventilation for comfort, as well as for asepsis and odor control in areas of facilities that directly affect patient care and are determined based on healthcare entities being predominantly "No Smoking" entities. Where smoking may be allowed, ventilation rates will need adjustment. Areas where specific ventilation rates are not given in the table shall be ventilated in accordance with American Society of Heating Refrigeration and Air-conditioning Engineers Standard 62-1989, Ventilation for Acceptable Indoor Air Quality, and American Society of Heating Refrigeration and Air-conditioning Engineers, Handbook of Applications, 1991 edition. Specialized patient care areas, including organ transplant units, burn units, specialty procedure rooms, etc., shall have additional ventilation provisions for air quality control as may be appropriate. Occupational Safety

and Health Administration (OSHA) standards and/or National Institute for Occupational Safety and Health (NIOSH) criteria require special ventilation requirements or employee health and safety within health care facilities.

2Design of the ventilation system shall provide air movement which is generally from clean to less clean areas. If any form of variable air volume or load shedding system is used for energy conservation, it must not compromise the corridor-to-room pressure balancing relationships or the minimum air changes required by the table. Except where specifically permitted by exit corridor plenum provisions of NFPA 90A, the volume of infiltration and exfiltration shall not exceed 15% of the minimum total air changes per hour, or 50 cfm, whichever is larger, as defined by the table.

3To satisfy exhaust needs, replacement air from the outside is necessary. Table 3 does not attempt to describe specific amounts of outside air to be supplied to individual spaces except for certain areas such as those listed. Distribution of the outside air, added to the system to balance required exhaust, shall be as required by good engineering practice. Minimum outside air quantities shall remain constant while the system is in operation.

4Number of air changes may be reduced when the room is unoccupied if provisions are made to ensure that the number of air changes indicated is reestablished any time the space is being utilized. Adjustments shall include provisions so that the direction of air movement shall remain the same when the number of air changes is reduced. Areas not indicated as having continuous directional control may have ventilation systems shut down when space is unoccupied and ventilation is not otherwise needed, if the maximum infiltration or exfiltration permitted in Note 2 is not exceeded and if adjacent pressure balancing relationships are not compromised.

5Air from areas with contamination and/or odor problems shall be exhausted to the outside and not recirculated to other areas. Note that individual circumstances may require special consideration for air exhaust to the outside.

6Recirculating room Heating, Ventilating, and Air Conditioning (HVAC) units refers to those local units that are used primarily for heating and cooling of air, and not disinfection of air. Because of cleaning difficulty and potential for buildup of contamination, recirculating room units shall not be used in areas marked "No." However, for airborne infection control, air may be recirculated within individual isolation rooms if 99.97% efficiency filters are used. Isolation and intensive care unit rooms may be ventilated by reheat induction units in which only the primary air supplied from a central system passes through the reheat unit. Gravity-type heating or cooling units such as radiators or convectors shall not be used in operating rooms and other special care areas. Recirculating devices with 99.97% efficiency filters may have potential uses in existing facilities as interim, supplemental environmental controls to meet requirements for the control of airborne infectious agents. Limitations in design must be recognized. The design of either portable or fixed systems should prevent stagnation and short circuiting of airflow. The supply and exhaust locations should direct clean air to areas where health care workers are likely to work, across the infectious source, and then to the exhaust, so the health care worker is not in a position between the infectious source and the exhaust location. The design of such systems should also allow for easy access for scheduled preventive maintenance and cleaning.

7The ranges listed are the minimum and maximum limits where control is specifically needed.

8Where temperature ranges are indicated, the systems shall be capable of maintaining the rooms at any point within the range. A single figure indicates a heating or cooling capacity of at least the indicated temperature. This is usually applicable when patients may be undressed and require a warmer environment. Additional heating may be required in these areas. Nothing in these rules shall be construed as precluding the use of temperatures lower than those noted when the patients' comfort and medical conditions make lower temperatures desirable. Unoccupied areas such as storage rooms shall have temperatures appropriate for the function intended.

9The infectious disease isolation room described here is to be used for isolating the airborne spread of infectious diseases, such as measles, varicella, or tuberculosis. The design of airborne infection isolation (AII) rooms should include the provision for normal patient care during periods not requiring isolation precautions. Supplemental recirculating devices may be used in the patient room, to increase the equivalent room air exchanges; however, such recirculating devices do not provide the outside air requirements. Air may be recirculated within individual isolation rooms if HEPA filters are used. Exhaust systems for infectious isolation rooms shall exhaust no other areas or rooms. Rooms with reversible airflow provisions for the purpose of switching between protective environment and AII functions are not acceptable.

10When required, appropriate hoods and exhaust devices for the removal of noxious gases or chemical vapors shall be provided. Laboratory hoods shall meet the following general standards:

1. Have an average face velocity of at least 75 feet per minute.
2. Be connected to an exhaust system to the outside which is separate from the building exhaust system.
3. Have an exhaust fan located at the discharge end of the system.
4. Have an exhaust duct system of noncombustible corrosion-resistant material as needed to meet the planned usage of the hood.

Laboratory hoods shall meet the following special standards:

1. Fume hoods and their associated equipment in the air stream, intended for use with perchloric acid and other strong oxidants, shall be constructed of stainless steel or other material consistent with special exposures, and be provided with a water wash and drain system to permit periodic flushing of duct and hood. Electrical equipment intended for installation within the duct shall be designed and constructed to resist penetration by water. Lubricants and seals shall not contain organic materials. When perchloric acid or other strong oxidants are only transferred from one container to another, standard laboratory fume hoods and associated equipment may be used in lieu of stainless steel construction. Fume hood intended for use with radioactive isotopes shall be constructed of stainless steel or other material suitable for the particular exposure and shall comply with National Fire Protection Association 801, Facilities for Handling Radioactive Materials, 1995 edition (NFPA 801).

NOTE: RADIOACTIVE ISOTOPES USED FOR INJECTIONS, ETC., WITHOUT PROBABILITY OF AIRBORNE PARTICULATES OR GASES MAY BE PROCESSED IN A CLEAN WORKBENCH-TYPE HOOD WHERE ACCEPTABLE TO THE NUCLEAR REGULATORY COMMISSION.

2. In new installations and construction or major renovation work, each hood used to process infectious or radioactive materials shall have a minimum face velocity of 150 feet per minute with suitable static pressure operated dampers and alarms to alert staff of fan shutdown. Each hood shall have filters with an efficiency of 99.97% (based on the diocetyl-phtalate test method) in the exhaust stream, and be designed and equipped to permit the removal, disposal, and replacement of contaminated filters. Filters shall be as close to the hood as practical to minimize duct contamination. Hoods that process radioactive materials shall meet the requirements of the Nuclear Regulatory Agency.

11Food preparation centers shall have ventilation systems whose air supply mechanisms are interfaced appropriately with exhaust hood controls or relief vents so that exfiltration or infiltration to or from exit corridors does not compromise the exit corridor restrictions of NFPA 90A, the pressure requirements of NFPA 96, or the maximum defined in the table. The number of air changes may be reduced or varied to any extent required for odor control when the space is not in use.