

Figure: 28 TAC §34.1302(d)

Code	GENERAL	FINE	Code	PATHWAYS/CORRIDORS OF EGRESS cont	Fine
34.817(m)	TRASH, cardboard or high grass within 10 ft of site	\$500.00	36.2.5.8	No clear exit path AROUND CHECKOUT aisle	\$250.00
34.832(12)	Supervisor less than 18 YEARS OLD (site closed until corrected)	\$500.00	7.11.5	Building has DEAD END CORRIDORS	\$150.00
34.832(12)	Individuals less than 16 YEARS OLD SELLING Fireworks	\$500.00	7.2.1.11.1	Turnstile, ropes or other DEVICES OBSTRUCT EGRESS	\$150.00
34.817(h)	Operator consuming or under influence of ALCOHOL	\$500.00		EXIT DOORS	
2154.252(c)	Fireworks sold or offered to CHILDREN under 16 years old or to an intoxicated or incompetent person	\$500.00	7.11.4	Less than TWO means of EGRESS if room >200 sqft	\$500.00
34.817(l)	No off highway PARKING provided	\$100.00	7.11.1	No EXIT WITHIN 75 ft of any point in the building	\$150.00
34.817(g)	SMOKING inside the site	\$500.00	7.7.1	Exits do not TERMINATE in open space (i.e. blocked)	\$150.00
34.817(g)	SMOKING outside within 10 feet of site	\$250.00	7.2.1.2.3.2	DOOR OPENINGS less than 32" wide	\$150.00
2154.202(g)	Selling fireworks OUTSIDE selling SEASON	\$250.00 TO \$500.00	7.2.1.4.2	Door "doesn't SWING OUT in direction of egress	\$250.00
	FIREWORKS STORAGE		7.2.1.3.1	Floor ELEVATION change Interior >½ or Exterior door >8"	\$100.00
34.832(6)	Stored fireworks in sales area ACCESSIBLE to public	\$100.00	7.2.1.3.3	THRESHOLD at door exceeds ½" in height	\$100.00
34.832(7)	Fireworks storage room not RESTRICTED to employees only	\$100.00	7.11.6	DOORS latch or lock not fire or PANIC HARDWARE	\$1,000.00
34.832(7)	"NO SMOKING" signs not posted in storage room	\$500.00	7.2.1.5.2	Doors have KEY LOCKS on egress side.	\$500.00
	STORAGE (and retail sales) OVER 500 CASES		7.2.1.4.1(3)	Ex (a&c) Not LOCKED OPEN when occupied	\$250.00
34.823(a2)	Not of SOLID CONSTRUCTION or sound engineering	Case	7.2.1.4.1(3)	Ex (b) No "This Door To Remain OPEN etc..." SIGN	\$100.00
34.823(a3)	Electrical does not meet NATIONAL ELECTRIC CODE	\$25.00 TO \$250.00	Code	EXIT DOORS (cont)	Fine
34.823(a3)	No outside MASTER ELECTRICAL SWITCH	\$250.00	7.2.1.4.1(3)	Ex (e) No ONE PANIC hardware door without a roll-up	\$500.00
34.823(a4A)	LESS 50ft from inhabited bldg(s) or surface of highways	\$500.00		SIGNS	
34.823(a4A)	Not in compliance with distances in TABLE 1 34.824	\$500.00	7.10.1.2.1	Not all exits have "EXIT" SIGNS. (if exit not obvious)	\$100.00
34.823(a4B)	WINDOWS or sunlight on fireworks not diffused	\$500.00	7.10.6.1.1	"EXIT" SIGNS NON-COMPLIANT with standard	\$500.00
34.823(a4C)	STOVE, exposed flame or electric heater in storage area	\$500.00	7.10.2.1	Missing DIRECTIONAL SIGNS to exits (if not apparent)	\$500.00
34.823(a4D)	Swing EXIT DOOR locked, not marked or obstructed	\$250.00	7.10.6.2.1	Directional SIGNS NON-COMPLIANT with standard	\$500.00
34.823(a4E)	No Class A EXTINGUISHER for each 1000 sqft of floor	\$100.00	7.10.8.3	Missing "NO EXIT" sign on doors that could be mistaken	\$250.00
34.823(a4F)	Brush, dry grass, leaves or COMBUSTIBLES within 10ft	\$100.00	34.817(g)	"NO SMOKING" sign not posted OUTSIDE entrance doors	\$100.00
34.823(a4G)	Missing "NO SMOKING" signs. (4" letters)	\$100.00	34.817(g)	"NO SMOKING" sign not posted INSIDE entrance doors	\$100.00
34.823(a5)	No fence, SECURITY ALARM or 24 hr. personnel on site	\$500.00	34.817(g)	"NO SMOKING" sign not posted several location inside	\$100.00
34.823(a6)	Class I COMBUSTIBLES (gasoline) less 100 ft from bldg	\$100.00	34.817(g)	"NO SMOKING" sign lettering less than 4 inches high	\$500.00
34.823(a6)	CLASS I dispensing or vents less than 100 ft from bldg (site closed)	\$500.00		EMERGENCY LIGHTING (if over 3000 sq.ft.)	
34.823(b1)	No SUPERVISOR at least 18 years old on duty (site closed until corrected)	\$500.00	36.2.9	No EMERGENCY LIGHTING provided	\$500.00
34.832(3A)	< 60ft from INHABITED bldg. (w/o permit before 11-18-02)	\$500.00	7.8.1.3	Emergency lighting doesn't ILLUMINATE paths of egress	\$250.00
34.832(3B)	< 30ft from PROPERTY line (w/o permit before 11-18-02)	\$250.00	7.9.2.1	Emergency lighting DURATION is less than 1½ hrs	\$250.00
34.832(3C)	Does not comply with TABLE 1 or have fire sprinklers	\$500.00	7.9.3.1.1	No RECORD of emergency lighting inspection & TEST	\$100.00
	PATHWAYS/CORRIDORS OF EGRESS			STRUCTURE	
36.2.5.5	Means of EGRESS/AISLES less than 36 inches	\$150.00	34.832(1)	Building is not FREE STANDING or durable	Case
36.2.5.10	Means of egress < 36" + CART LENGTH (if using carts)	\$150.00	34.832(1)	Mezzanine or 2nd STORY accessible to the public	\$150.00
34.817(e)	Path to exit door OBSTRUCTED	\$250.00	34.832(1)	Selling from a TENT, boat, or mobile vehicle (site closed)	\$500.00
7.1.10.1	Egress not CONTINUALLY FREE of obstructions	\$150.00	34.817(k)	Bldg. single or multi-family RESIDENTIAL STRUCTURE (site closed)	\$500.00
Code	STRUCTURE cont	Fine	Code	STAIRS	Fine
34.832(1)	Sales area Multi-Use (other business) or MULTI-TENANT (site closed)	\$500.00	7.2.2.2.1	RISER not 4"-7" or TREADS less than 11" wide	\$100.00
34.832(18)	Sales area >2500 sqft with ave. CEILING HEIGHT < 12 ft	\$500.00	7.2.2.2.1.2	Less than 36" WIDE or < 56" wide if occupancy over 2000	\$100.00
34.832(10)	Stored behind glass with impinging direct SUNLIGHT	\$500.00	7.2.2.3.3.1	Stairs treads not SOLID	\$100.00
34.832(14)	No outside MASTER electrical switch	\$100.00	7.2.2.4.1.1	No HANDRAILS 34" to 38" high provided	\$100.00
9.1.2	Electrical WIRING and equipment APPEAR HAZARDOUS	\$25.00 TO \$250.00	7.1.8	Open stairs over 30" rise without a GUARD RAIL	\$100.00
	INTERIOR			STAIR LANDINGS	
34.832(5)	Inadequate PREVENTION of customers handling fwks	\$100.00	7.2.2.3.2.1	No LANDING at door opening	\$100.00
34.832(5)	RESTRAINT around displayed fireworks not durable	\$100.00	7.2.2.3.2.3	Landing LENGTH in direction of travel is less than width.	\$100.00
34.832(5)	Customers HANDLING fireworks w/o attendant assistance	\$500.00	7.2.2.3.3.1	Horizontal landing not SOLID (i.e. grating or see through)	\$100.00
34.832(9)	small quantities of unused BOXES in sales/storage area	\$500.00		HANDRAILS	
34.832(11)	EXTENSION CORD located where public can walk over	\$500.00	7.2.2.4.4.1	Not 34" to 38" HIGH above leading edge of tread	\$100.00
34.832(11)	EXTENSION CORD supplies > one device w/o power strip	\$500.00	7.2.2.4.4.5	Less than 2¼" CLEARANCE between rail and wall	\$100.00

34.832(11)	EXTENSION CORD unprotected from accidental damage	\$50.00		7.2.2.4.4.6	Handrails are not a CIRCULAR cross-section of 1½" to 2"	\$100.00
34.832(11)	EXTENSION CORD used in lieu of fixed structural wiring	\$25.00		7.2.2.4.4.7	Rail is not CONTINUOUS	\$100.00
34.832(11)	Power STRIP without internal circuit breaker	\$25.00		7.2.2.4.4.6	Improper TERMINATION or EXTENSION of rail	\$100.00
34.832(13)	Trash CONTAINERS not METAL or heavy plastic	\$25.00			GUARD RAILS	
34.832(13)	Trash CONTAINERS < 10ft AWAY from fireworks	\$250.00		7.1.8	No GUARD RAIL where egress is > 30" above floor/grade	\$100.00
34.832(15)	SPACE HEATER in sales/storage areas	\$100.00		7.2.2.4.5.2	Guard RAIL is less than 42" high.	\$100.00
34.832(17)	COOKING EQUIPMENT in sales/storage areas	\$100.00		7.2.2.4.5.3	Over 4" between any point in VERTICAL RAILS up to 34" high	\$100.00
34.817(d)	No 2A EXTINGUISHER per 2,000 sqft & within 75 ft travel	\$500.00			RAMPS	
34.817(p)	Internal combustion ENGINES operating inside retail site	\$500.00		7.2.5.3.2(1).	No LANDING at top, bottom or at door openings.	\$100.00
36.3.3.2	Interior wall and ceiling FINISH is not type Class A or B	\$500.00		Tab 7.2.5.2	Single ramp in excess of a 30° RISE.	\$100.00
6.1.14.4.1	No FIREWALL -Btwn High Hazard & other occup > 200 sqft	\$500.00		Tab 7.2.5.2	SLOPE in excess of 1 in 8	\$100.00
	PAPERWORK			Tab 7.2.5.2	Less than 30" WIDE	\$100.00
34.817(j)	Original permit not posted in sales area	\$100.00		7.2.5.3.1(1)	Not permanent FIXED construction	\$100.00
34.817(j)	No permit (site closed until corrected)	\$500.00		7.2.5.3.1(4)	Not SOLID construction.	\$100.00
34.832(8)	Local FD or County FD not NOTIFIED of location in writing	\$100.00		7.2.5.4	No GUARD or HANDRAIL on ramp with rise over 6"	\$100.00
34.832(16)	PLAN not on file at SFMO office (site closed until corrected)	\$250.00			BULK MERCHANDISING >12,000 sqft	
	FIREWORKS			36.4.5	Violation(s) of Bulk Merchandising requirements	Case
2154.003	Illegal fireworks e.g. Bottle or Pop Rockets, M-80's	\$1,000.00			OTHER NFPA LIFE SAFETY CODE	
2154.003(b)	ILLEGAL fireworks (Bottle or Pop Rockets, M-80's)	\$1,000.00				
2154.251(2)	Sell <100' from storage and dispensing of flammables (closed until corrected)	\$500.00		34.832(19)	Violations of NFPA 101 the Life Safety Code®	Case
34.817(o)	Fireworks do not conform to USCPS LABELING	\$500.00		9.1.2	One or more FAULTS identified on Receptacle tester	\$25.00
34.817(i)	OTHER than fireworks or fireworks promotional items	100.00				